

EC Type Examination Certificate for Safety Components for Lifts

This is to certify that:

T.A. Savery and Company Limited
T/A Oleo International
 Grovelands Estate
 Longford Road
 Exhall
 Coventry
 CV7 9NE
 United Kingdom

Holds Certificate Number:

BSI-LB-616622

In respect of:

Energy Dissipation Buffer model HSL72

on the basis of our examination under the requirements of Council Directive 95/16/EC, Annex V:A (module B) the Lift Directive, as recorded in BSI Report No. 289/8181192 1 of 2 dated 14 August 2014.

For and on behalf of BSI,
 a Notified Body for the above Directive
 (Notified Body Number 0086):



Gary Fenton, Global Assurance Director

Any modification to the design of this product will invalidate this EC Certificate and the Notified Body, number 0086, must be informed without delay.

First Issued: 29 August 2014

Issue 1
 Page 1 of 3

Date: 29 August 2014

...making excellence a habit.™

EC Type Examination Certificate for Safety Components for Lifts

No. BSI-LB- 616622

Limitations of Certificate Validity

This EC type-examination certificate is only valid when an Energy Dissipation Buffer model HSL72 is installed to operate under the following conditions:

1. For use with a minimum mass of 4000 kg.
2. For use with a maximum mass of 10000 kg.
3. With a maximum rated speed of up to 7.25 m/s.
4. With a maximum impact speed of up to 8.34 m/s.
5. For use with hydraulic fluid type that meets ISO VG 68.
6. Hydraulic fluid capacity of 144 Litres.
7. With a buffer stroke height of 3.650 m.



First Issued: 29 August 2014

Issue 1
Page 2 of 3


Date: 29 August 2014

...making excellence a habit.™

EC Type Examination Certificate for Safety Components for Lifts

No. BSI-LB- 616622

Energy Dissipation Buffer model HSL72



First Issued: 29 August 2014

Issue 1
Page 3 of 3

Date: 29 August 2014

...making excellence a habit.™